



1215 Houbolt Road
Joliet, IL 60431

July 13, 2010

To: **All Bidders**

Re: **Joliet Junior College, Illinois Community College District No. 525
Master Facilities Plan Phase 2, Automotive Building Expansion Work Bid Release 17
1215 Houbolt Road, Joliet, Illinois 60431**

**Bid Package 02H – Sitework & Cast-In-Place Concrete Work
Bid Package 03B – Precast Concrete Work
Bid Package 05C – Structural and Miscellaneous Steel Work
Bid Package 06H – General Trades Work
Bid Package 07C – Roofing Work
Bid Package 15I – Plumbing Work
Bid Package 15J – HVAC & Mechanical Piping Work
Bid Package 16I – Electrical / Fire Alarm / Security / Telecommunication Work**

Subject: **Supplement No. 4**

Please be advised of the following supplemental information which is to be included in the Proposal as it pertains to the above referenced Bid Packages. This Supplement is issued to modify, explain and/or clarify the original Bid Documents.

General Instructions to All Bidders

- A. The Bid Proposal due date for all Bid Packages REMAINS Thursday, July 15, 2010 at 9:00 a.m. at Joliet Junior College, 1215 Houbolt Road, Joliet, Illinois 60431. The bids are to be dropped off at Room H1018/H1019 and they will be opened in Rooms J0006 and J0007. Please note that H1018 is an interior office space that is located inside Room H1019.**
- B. All bidders are reminded that by submitting a bid, the bidder agrees to the content of the Bid Forms, Site Logistics Plan, Milestone Schedule Dates, Quality Plan, and Safety Plan provided with the Bid Documents.**
- C. Please note the Bid Bond is to be drawn in favor of Joliet Junior College, Illinois Community College District No. 525 of Joliet, Illinois.**
- D. Incorporate into the bid documents the architect's Addendum No. 3 dated July 12, 2010, attached.**

All other terms and conditions of the Bid Documents remain the same.

Acknowledge receipt of this Supplement No. 4 in your Proposal Form.

Sincerely,

GILBANE BUILDING COMPANY

Roz Thomas

Roz Thomas
Purchasing Agent



8550 West Bryn Mawr Avenue
Suite #500
Chicago, Illinois 60631
Telephone 773-695-3500
Facsimile 773-695-3501

DIVISION 0 – REVISIONS, CLARIFICATIONS, AND MODIFICATIONS
SECTION 009113 – ADDENDUM 3

Date: July 12, 2010

From: Wight & Company
2500 N. Frontage Rd.
Darien, IL 60561
(630) 969-7000 phone
(630) 969-7979 fax

To: All Bidders of Record

Subject: **Addendum No. 3 to the Bid Documents for:
Joliet Junior College - Automotive Service Technology Expansion
1215 Houbolt Road
Joliet, IL 60431**

Bid Package: 17

Arch. Proj. No. 02-5236-01

This Addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated June 9, 2010. Acknowledge receipt of this addendum in the space provided on the Bid form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

GENERAL

1. Drawing P5.00, Detail 6: Clarification - The Triple Garage Basin Detail is a schematic graphic representation of the intended receptor for the floor and trench drains in both the new Commercial Shop 1076 and the Existing Lab Shop 1001.
 - a. The 132" depth indicated in note 2 under the detail is measured from the invert of the inlet/outlet pipes to the bottom of the basin.
 - b. The inverts are indicated on P2.00 to be 563.56.
 - c. Bottom of basin elevation would be 11.00' (132") below the invert, or 552.56.
 - d. Referencing Civil Drawing C5.00, the grade elevation at the concrete pad for this triple basin is approximately 573.00.
 - e. Therefore, total depth of the triple garage basin from grade to bottom of basin is approx. 573.00 – 552.56, or approx. 20.44'.