

Addendum No. 1

Page 1 of 1

DATE: November 10, 2010

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders
SUBJECT: Addendum No. 1
PROJECT NAME: Sub B MCC Replacement
JJC PROJECT NO.: B10048

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

Clarifications:

Arch Flash Label

The contractor shall furnish an Arch Flash Label per the engineer's direction.

Hours for Shut Down

Contractor shall base their bid on weekend shut down.

Salvage of existing equipment

Contractor shall salvage one newer breaker from existing. All older equipment shall be discarded and removed from the site by the contractor.

Pipe insulation interference at existing MCC

Previous testing has indicated that straight pipe insulation is non-hazardous material. Repair of the pipe insulation following removal of the existing MCC will be by JJC.

END OF ADDENDUM