

Addendum No. 2

Page 1 of 1

DATE: March 11, 2011

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders

SUBJECT: Addendum No. 2

PROJECT NAME: C – E Washroom Renovations

JJC PROJECT NO.: B11016

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

No contractor questions were submitted by the due date/time.

1. The contractor is to include providing ground penetrating radar floor scans to verify any areas requiring saw cutting or core drilling of the existing concrete floors. Existing concrete floors are post-tensioned slabs with cables.