



1215 Houbolt Road
Joliet, IL 60431



8550 West Bryn Mawr Avenue
Suite #500
Chicago, Illinois 60631
Telephone 773-695-3500
Facsimile 773-695-3501

May 11, 2011

To: **All Bidders**

Re: **Joliet Junior College, Illinois Community College District No. 525
Master Facilities Plan Phase 1, Campus Center Building Work, Bid Release 26
1215 Houbolt Road, Joliet, Illinois 60431**

06L – General Trades Work
09N – Resilient Flooring Work
15R – Mechanical Work
16M – Electrical & Technology Work

Subject: **Supplement No. 3**

Please be advised of the following supplemental information which is to be included in the Proposal as it pertains to the above referenced Bid Packages. This Supplement is issued to modify, explain and/or clarify the original Bid Documents.

General Instructions to All Bidders

- A. The Bid Proposal due date for all Bid Packages REMAINS Friday, May 13 2011 at 2:00 p.m.** at Joliet Junior College, 1215 Houbolt Road, Joliet, Illinois 60431. The bids are to be dropped off at Room H1018/H1019 and they will be opened in Room J0006-J0007. Please note that H1018 is an interior office space that is located inside room H1019.
- B.** All bidders are reminded to include the Bid Proposal Forms, Schedule Dates, Quality Plan and Safety Plan requirements in their bid.
- C.** Incorporate into bid documents the responses to the following bidder inquiries into the scope of work:

Bid Package 06L – General Trades Work

- 1. Question:** Regarding sketch ASK-06 - Are we installing new flooring in the server room where it is marked New. Confused on what we are to do.
Response: The words, "New" and "Existing" refer to the areas of access flooring. This is more clear if you look at the full detail in the drawings. The access flooring has a finished surface, so no flooring material is required on the access flooring, except where noted at the ramp and tactile warning strip at the steps. Per ASK-12 there is base required at walls north of centerline D (all new walls) within the Server Room, as well as base and VCT on the floor at the base of the ramp.

Bid Package 16M – Electrical and Technology Work

- 2. Question:** I just received Supplement #2 and I, along with most of the Technology subcontractors, am not clear on Bid Package 16M, Question 21. It states, "Access control systems are being provided and will be tying into the existing Access Control server system. Video...." Provided by whom? Our bid form scope of work is clear regarding the other systems, but not the access control. What are we to include in our bid?
Response: Please see the Access Control Matrix of Responsibilities in Specification Section 08 71 00.10.

All other terms and conditions of the Bid Documents remain the same.

Acknowledge receipt of this Supplement No. 3 in your Proposal Form.

Sincerely,

GILBANE BUILDING COMPANY

Roz Thomas

Roz Thomas
Senior Purchasing Agent