

Addendum No. 1

Page 1 of 1

DATE: September 16, 2011

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders

SUBJECT: Addendum No. 1

PROJECT NAME: Roof Replacement - T Building

JJC PROJECT NO.: B11042

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

Clarification #1:

Sheet G100, GENERAL NOTES, C: BIDDING NOTES, note 2: The construction start and completion dates are to be as indicated in the pre-bid meeting agenda.

Clarification #2:

Sheet A200, Existing Roof Core Sample Log: The core sample #2 at the southwest end of the project near the hydronic piping also indicated that insulation was wet as well as the concrete roof deck.

Clarification #3:

Coping metal finish color shall match Pac-Clad Slate Gray.

Additional Addendum Item #1:

Drawing M-100, Site Plan Mechanical, for the Health Professions Center is included as part of this addendum for reference in regard to new piping supports to be installed on the T Building roof. Roofing work required at the new supports will be as detailed for the existing supports and shall be included in the contractors scope.

End of Addendum #1

