

# Addendum No. 1

Page 1 of 2

**DATE:** October 17, 2011

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Bidders

**SUBJECT:** Addendum No. 1

**PROJECT NAME:** Data Center Cooling Installation REBID

**JJC PROJECT NO.:** B11043R

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

## **Clarification #1:**

The following corrections to the Pre-Bid Meeting Agenda were noted:

Item #4: Delete (by others) after the word conduit.

Item #10: Change October 11 to November 8.

Item #14: Revise the first three lines as follows:

- Sign and turn-in Certificate of Contract/Bidder with bid (pg 169)
- Sign and turn-in Certificate of Compliance w/ Illinois Drug Free Workplace Act (pg 170)
- Page 171 starts Bid Form

## **Clarification #2:**

The contractor shall include a \$7,500 allowance in the Base Bid as noted on Sheet M-112, GENERAL NOTES, Note 9.

## **Clarification #3:**

The existing UPS battery racks currently located where the Liebert unit is to be located will be moved by others.

## **Clarification #4:**

The contractor is responsible for required modifications and rework of the existing raised flooring system as noted on Sheet M-112.

**Additional Addendum Item #1:**

**Question:**

In regards to the relocation of some of the fire suppression devices to the opposite side of the door.  
Who is your vendor that supports this system?

**Answer:**

The existing Fenwal Novec 1230 Fire suppression system has been serviced by Phoenix Fire Systems, 744  
Nebraska Street, Frankfort, IL 60423, Phone 815-464-9300.

**End of Addendum #1**