



Addendum No. 1
Page 1 of 1

DATE: December 19, 2013

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders
SUBJECT: Addendum No. 1
PROJECT NAME: Security Cameras Phase V
JJC PROJECT NO.: B14001

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

JJC Items:

Contractor pricing is to be inclusive of mounting JJC supplied cameras. Contractor will work along with state contract vendor (under separate contract with JJC) when mounting cameras. State vendor shall point and focus cameras. All necessary lifts will be provided by this contractor.

Hardware for mounting the cameras will be provided by JJC.

It was stated in the pre-bid meeting that JJC would provide the patch cable to the switches. However, this addendum clarifies that all data cabling from cameras to switches, IDF's, etc. are to be provided and installed by the contractor.

Contractor is responsible for tracing of any existing wiring as required.

Any data cable that is required to be provided by contractor shall be Panduit PUP6504WH-UY.

Contractor shall include a \$10,000 allowance in their bid for unforeseen/miscellaneous conditions. When figuring this allowance within the bid, contractor is to include all necessary overhead and profit. This allowance is not for the contractor's benefit, and is only authorized to charge against this allowance when directed and approved by Joliet Junior College. The contractor will be allowed to invoice for material and labor costs only.

See drawing EC-4 included in this addendum that shows each IDF room location for cameras mounted to the buildings.

End of addendum #1