



**Addendum No. 2**  
**Page 1 of 2**

**DATE:** April 19,2021

Joliet Junior College  
1215 Houbolt Road  
Joliet, IL 60431

**TO:** Prospective Bidders  
**SUBJECT:** Addendum No. 2  
**PROJECT NAME:** City Center Site Work  
**JJC PROJECT NO.:** B20045

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

---

**Bid Day/Date Clarification from Pre-Bid Agenda:**

- Bids due date: **Tuesday, April 20, 2021 at 9:00 am**

**Drawing Revisions:**

1. General All plan sheets bear a revision date of 4/12/2021, Addendum 2
2. Sheets 1-2/18 No further revisions
3. Sheet 3/18 Revision of quantities for items 38, 39, 40, 52, 53, 54, 55, 56, 57, 59, 60, 61
4. Sheets 4-5/18 No further revisions
5. Sheets 6-7/18 Two bollards have been added within the trash enclosure
  - i. The parking lot has been shifted 1.5 feet east per IDOT request
6. Sheet 8/18 The parking lot has been shifted 1.5 feet east per IDOT request
7. Sheets 9-10/18 No further revisions
8. Sheet 11/18 The parking lot has been shifted 1.5 feet east per IDOT request
9. Sheet 12/18 The restrictor manhole has been modified per IDOT request
10. Sheets 13-14/18 No further revisions
11. Sheet 15/18 Additional parking lot lights, including conduit revisions
  - i. The electrical service handhole has had details added
12. Sheets 16-18/18 No further revisions
13. Sheets L1-L3/L3 No further revisions

**Specification Revisions:**

## Schedule of Prices

1. Provide the attached Schedule of Prices bearing a footer of "Addendum2, April 16, 2021" with the completed bid
2. Revision of quantities for items 38, 39, 40, 52, 53, 54, 55, 56, 57, 59, 60, 61
3. Revision of the bid unit for Item 71, Construction Staging and Pedestrian Access Management, from Per Day to Lump Sum

**Response to Questions Received:**

1. Can we get more information on the memorial plaque and base please? What is it? Specs?
  - a. *The plaque and base are not part of the scope of work.*
2. Can the sidewalk control joints be saw cut?
  - a. *Control joints may be cut. Expansion joints and cold-joints must be cast with preformed joint filler.*
3. Unfortunately, we do not do take-offs at Chicago Cut due to the many site variables and things to that nature. For all the work that we've done for any Contractors in the past, their Estimators would simply tell us what the take-offs were. So, if you could tell me the trench size, width & depths, or how much Wall sawing or Core drilling there is etc... I can get you over some numbers.
  - a. *Standard trench details are provided on the drawings.*

**End of Addendum #2**