



Addendum No. 1
Page 1 of 1

DATE: April 22, 2019

Joliet Junior College
1215 Houbolt Road
Joliet, IL 60431

TO: Prospective Bidders
SUBJECT: Addendum No. 1
PROJECT NAME: J Bldg AHU Replacement
JJC PROJECT NO.: B18036

This Addendum forms a part of the Bidding and Contract Documents and modifies the original bidding document as posted on the JJC website. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

-
1. The \$10,000 allowance line item provided for on the bid form shall be supersede the \$5,000 allowance called for on the drawings.
 2. During the walk-thru of the mechanical rooms, the question was asked regarding the depth of the sewage ejector pit. It was thought the pit was approximately 6 feet deep. However, upon further investigation it was determined the depth is approximately 12 feet deep.

End of Addendum #1